



PSB Singapore

CERTIFICATE OF CONFORMITY

No. CLS2 16 07 80848 002

Certificate Holder:	DEC Engineering Corporation 4FL , SangHa Building, 234-26, Nonhyun-Dong, Gangnam-Gu Seoul 135-830 REPUBLIC OF KOREA
Product:	Composite Panels
Brand Name:	ALCOMEX Fr
Model(s):	ALCOMEX Fr
Product Details:	Area Density: 7.4kg/m ² Tested on the mineral FR core face (Rating: Class 0)
Standard(s):	BS 476-6:1989/A1:2009 BS 476-7:1997
Country of Origin:	Republic of Korea
Test Report(s):	7191016895-MEC11/1-OKH, 7191016895-MEC11/2-YWA
Issued on:	2016-07-11
Valid until:	2019-07-10

Vice-President (Certification Department)
TÜV SÜD PSB

This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of TÜV SÜD PSB Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking TÜV SÜD PSB's website at www.tuv-sud-psb.sg



Cert No: PD-2002-01